



**AFITI**  
**LICOF**

Centre for Fire Testing  
and Research

Association for the Promotion of Research and Fire Safety Technology

# Test Certificate

**Nr: C2873T15(English Version)**

**Applicant** **METECNO ESPAÑA, S.L.**  
Pol. Ind. "Bayas", Parcela 107- 110  
09200 – MIRANDA DE EBRO (Burgos)

**Building material** Metallic sandwich panel with PIR core.  
Manufacturer: Metecno España, S.L.

Commercial trade name	Commercial trade name
<b>FRIMET TP-SM</b>	<b>GLAMET G5</b>
<b>FRIMET BT-LM</b>	<b>GLAMET G3</b>
<b>MONOWALL</b>	<b>METCOVER TJG3</b>
<b>SUPERWALL</b>	<b>METCOPPO</b>

**Tests** Test according UNE-EN 13823:2012+A1:2016, "Reaction to fire tests for products – Building products excluding floorings exposed to the thermal attack by a single burning item" standard.

Test according UNE-EN ISO 11925-2:2011, "Reaction to fire tests. Ignitability of building products subjected to direct impingement of flame. Part 2: Single flame source test "

**Test dates** 14<sup>th</sup>-jul-15, 16<sup>th</sup>-jul-15 and 29<sup>th</sup>-jul-15

**Certificates of reports** Test report Nr 2873T15 (issued by AFITI-LICOF with date 08<sup>th</sup>-Oct-15).  
Classification report Nr. 2873T15-2.R1 (issued by AFITI-LICOF with date 03<sup>rd</sup>-Mar -17).

## Reaction to fire classification

**B-s1,d0**

Classification according to UNE-EN 13501-1:2007+A1:2010 "Fire classification of construction products and building elements- Part 1: Classification using data from reaction to fire tests".

Toledo, 08<sup>th</sup> of October of 2019



Fdo: David Sáez García  
Technical Director of  
Reaction to Fire Laboratory

*This Test Certificate contains the English version only from the spanish TestCertificate Report dated 29<sup>th</sup>-November-18. In case of doubt, the Spanish version Test Report prevails.*

The results of this Certificate refer solely and exclusively to the specimens tested, and not to the product in general. The specified reports include important aspects of the test performance and development which have made it possible to obtain the aforementioned Reaction to Fire classification. This certificate should be used together with the referenced reports. Cancellation or modification of the aforementioned reports implies cancellation or modification of this certificate.

**HEAD OFFICE & LABORATORIES** Camino del Estrechillo, 8  
E-28500 Arganda del Rey - Madrid (Spain)

**CENTRAL OFFICE & LABORATORIES** C/ Río Estenilla, s/n - P.I. Sta. Mª de Benquerencia  
E-45007 Toledo (Spain)

+34 902 112 942  
+34 901 706 587  
@ licof@afiti.com  
www.afiti.com