



Test Certificate

Nr: C3490T18(English Version)

Applicant **METECNO ESPAÑA, S.L.**
Pol. Ind. "Bayas", Parcela 107- 110
09200 – MIRANDA DE EBRO (Burgos)

Building material Metallic sandwich panel with PUR B-2 core.
Manufacturer: Metecno España, S.L.

Commercial trade name	Commercial trade name
GLAMET G3	ONDACOPPO
GLAMET G5	FRIMET
METECNO ROOF G5	MONOWALL
METECNO ROOF G3	METECNO WALL
METCOPPO	SUPERWALL
COPPO	METCOVER TJ G3

Tests Test according UNE-EN 13823:2012+A1:2016, "Reaction to fire tests for products – Building products excluding floorings exposed to the thermal attack by a single burning item" standard.

Test according UNE-EN ISO 11925-2:2011, "Reaction to fire tests. Ignitability of building products subjected to direct impingement of flame. Part 2: Single flame source test"

Test dates 16th-may-18, 17th-may-18 and 05th-jun-18

Certificates of reports Product type Test report Nr 3490T18 (issued by AFITI-LICOF with date 14th-Jun-18).

Reaction to fire classification

B-s2,d0

Classification according to UNE-EN 13501-1:2007+A1:2010 "Fire classification of construction products and building elements- Part 1: Classification using data from reaction to fire tests".

Toledo, 08th of October of 2019



Fdo: David Sáez García
Technical Director of
Reaction to Fire Laboratory

This Test Certificate contains the English version only from the spanish TestCertificate Report dated 20th-June-18. In case of doubt, the Spanish version Test Report prevails.

The results of this Certificate refer solely and exclusively to the specimens tested, and not to the product in general. The specified reports include important aspects of the test performance and development which have made it possible to obtain the aforementioned Reaction to Fire classification. This certificate should be used together with the referenced reports. Cancellation or modification of the aforementioned reports implies cancellation or modification of this certificate.